

The Utilities Board of the
City of Gulf Shores
Clarifier Additions
at the
Water Reclamation Facility

Addendum 1

Contract documents and drawings shall be revised or replaced as follows:

1. Revised Bid Date – The bid date and time is hereby revised to 2:00 P.M. on Thursday July 20, 2017.
2. Contract Time – In the Special Conditions, the contract time shall be revised to read 250 calendar days.
3. Replace Drawing Sheets 7 and 10 with the attached revised Sheets 7 and 10.

Clarifications:

1. The existing elevations at the center of the two new tanks is approximately 7.5 for the east clarifier and 7.6 for the west clarifier.
2. The top elevation for the new manhole adjacent to the motor control center is 9.40.
3. The inverts of the piping below the splitter box and at the connection points to the existing 24” mains to the existing clarifiers is approximately 0.3 +/-.
4. Clarifier equipment will be shop primed. Primer shall be touched up after assembly and one complete finish coat shall be applied as specified.
5. All concrete surfaces or exposed piping inside of the clarifiers shall be painted by the Contractor. Concrete and exposed piping external to the clarifiers shall be painted by the Owner.
6. Grout for the clarifier floors shall be cement based, non-shrink grout meeting ASTM C1107 and CRD-C621 specifications. Grout shall be designed for underwater applications and shall be applied to concrete floor using approved bonding agent.
7. Gate valves shall be manufactured by Clow, Mueller, or approved equal. Valves shall be resilient wedge type with 2” operating nut for buried service and operating wheel for above ground service. Buried

gate valves shall be furnished with an adjustable iron valve box with 24"x24"x4" thick, poured in place concrete collar at final grade.

Valve boxes not centered over the operating nut shall be replaced at no additional cost to the Owner.

8. Check valves shall be manufactured by Clow, Mueller, or approved equal and shall be provided with weight and lever.
9. All references in the contract documents using the term "Architect" shall be changed to "Engineer."

NOTE: A SIGNED COPY OF THIS ADDENDUM MUST ACCOMPANY THE BID.

BIDDER:

SIGNATURE:

DATE: