

BURK-KLEINPETER, INC.

ENGINEERS, ARCHITECTS, PLANNERS, ENVIRONMENTAL SCIENTISTS
2900 8TH STREET
TUSCALOOSA, AL 35401
PHONE (205) 759-3221 FAX (205) 759-9166

ADDENDUM NUMBER 5

B Street Water Treatment Plant & North Water Treatment Plant Improvements

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated January 7, 2020.

ITEM NO. 1 – CLARIFICATION ON EXISTING PAINT IN THE B STREET WTP PIPE GALLERY:

There have been several questions about whether the existing paint in the pipe gallery contains lead. EPA recognized lead test kits have been used to test for lead-based paint on the walls, pipe and catwalk within the pipe gallery. These tests all returned a negative result, indicating that there was no lead content at or above the regulated level in the areas tested. Lead abatement, as previously stated in Addendum No.1, is no longer required.

ITEM NO. 2 – CLARIFICATION TO FLOW METER REQUIREMENTS AT B STREET WTP:

It has come to our attention that there is conflicting information regarding the replacement of the flow meters in the pipe gallery at the B Street WTP. The intent in this project is to remove the existing Venturi Meters and replace them with new Magnetic Flow Meters.

ITEM NO. 3 – CLARIFICATION LUMP SUM BID:

The conversion of the project to Lump Sum Bid has not eliminated any items of work from this project. The Filter Basin Coating is part of the Lump Sum Base Bid. Coating of the pipe, walls and ceiling in the pipe gallery is part of the Alternate No. 1 Bid.

When submitting bid, please be sure to acknowledge that you have received this addendum.