

Stantec Consulting Services Inc.
3052 Beaumont Centre Circle, Lexington, KY 40513-1703
Phone: (859) 422-3000
Fax: (859) 422-3100

Project: Big Creek Lake Dam Gate Automation
Addendum No: 3
Date: April 23, 2020
Owner: MAWSS
Contract No. 175668273

This addendum is to be read with and constitutes part of the bid documents.

Instructions to Bidders:

Amend your copy of the bid documents in accordance with the detail below
Retain one copy for your file; sign and return a second copy and attach to your proposal as confirmation that the Addendum was taken into account in your bid proposal.
Failure to sign and return this form may result in a non-compliant bid.

Details of the Addendum:1. Clarifications and Revisions:

- a. Addendum No. 2 included a revision to Section 41 22 23.23, Paragraph 2.4.B.1. concerning the duty rating for the motors for the actuators. The original requirement was for motors to have a continuous duty rating. Addendum No. 2 relaxed this requirement to a minimum 30-minute duty rating. After further discussion with MAWSS, the requirement has been further revised. This requirement shall be modified such that the motor for each actuator shall have a minimum 15-minute duty rating.

2. Questions from Plan Holders and Responses: No responses to questions are being issues as part of Addendum No. 3.

3. Attachments: No attachments are included as part of Addendum No. 3.

Stantec Consulting Services Inc.

Kip Anderson PE, PG
Principal, Senior Geotechnical Engineer

Phone: 859-422-3074
Kip.Anderson@stantec.com



John Spalding PE
Project Engineer

Phone: 941-907-6900
John.Spalding@stantec.com

Name of Firm

Authorized Signature

Printed Name

_____ Date _____