



SPEAKS & ASSOCIATES
CONSULTING ENGINEERS, INC.
 732 OAK CIRCLE DRIVE WEST
 MOBILE, ALABAMA 36609
 PHONE: (251) 666-4646 FAX: (251) 666-8868

Mikell D. Speaks, PE/PLS
William G. Luker, PE/PLS
J. William Parkes, PE
John A. Sprinkle, PE
Jeremy O. Turner, EI

Water Supply Improvements for the CWM Water Authority
Contract A – R.O. Water Treatment Plant and Contract B – R.O. Treatment Equipment

August 4, 2022

ADDENDUM NO. 4

To all bidders on the above-named project:

The following changes, additions, and/or revisions shall be made to the bidding documents:

1. For the water line work, all pipe will be installed by open-cut type construction. On the Proposal, change the length of pipe for Item 4W to "0".
2. Delete all references to lime feed equipment on the drawings or in the specifications. This equipment is not required.
3. For the building, the two roll-up doors indicated shall be as follows:

Rolling Service Door Systems, 18 ga. #625 Stormtite insulated with:

- Chain hoist operation
- Galvanized steel front and back
- Slide lock
- Full weatherstripping
- Industrial grade White Powder Coat finish (Powderguard Max)

Acceptable Manufacturer: Overhead Door Corporation, 2501 S. State Hwy. 121, Suite 200, Lewisville, TX 75067; ASD. Tel. Toll Free: (800) 275-3290; phone: (469) 549-7100; fax: (972) 906-1499; website: www.overheaddoor.com; email: info@overheaddoor.com

Other comparable products will be considered.

A copy of this addendum, signed by the bidder's authorized representative, must accompany each bid. In addition, please email (brendah@speaks.cc) or fax (251-666-8868) a signed copy back to Speaks & Associates by noon on Monday, August 8, 2022 to acknowledge receipt.

Speaks & Associates
 Consulting Engineers, Inc.

William G. Luker

William G. Luker, PE/PLS
 WGL/bh

Company Name _____

By _____
 (Signature of authorized representative)

Title _____